

## ActiV Conventional Hi-Output W-2.75-9 Wall VAD c/w Voice Sounder (shallow base)

Part No. **BF447C/CC/SR**

**C-TEC  
Manufactured**



### Overview

- Provides 'W-2.75-9' rated light distribution when wall mounted (min. 0.4 lux over a 2.75 x 9m cuboid area). Can also be used as a W-4-4 VAD.
- Superb sound intelligibility.
- Choose from two evacuation voice messages and four evacuation alarm tones (your selected evacuation message will be preceded by the selected tone).
- Three selectable VAD flash rates (0.5Hz, 1Hz, OFF)
- Alarm Current at 30Vdc = 17mA (0.5Hz) or 24mA (1Hz)
- Alarm Current at 18Vdc = 18.5mA (0.5Hz) or 30mA (1Hz)
- IP21C rated.
- Manufactured in the UK by C-TEC.

### More Information

### Technical Specifications

Protocol/compatibility	Compatible with C-TEC's CFP, FP, MFP and EP203 conventional fire alarm panels and virtually all other makes (testing on third-party panels is recommended before use)
Application/operation	Designed to be wall mounted. Indoor areas only.
VAD category & coverage	W-2.75-9 rated light distribution (min. 0.4 lux over a 2.75m x 9m cuboid area). Can also be used as a W-4-4 VAD.
Flash rate & colour	0.5Hz; 1Hz or OFF / White.



Supply/operating voltage	18 to 30V DC.
Nominal SPL (Sound Pressure Level)	88dB(A) @ 1m.
Alarm current	At 30Vdc: 17mA (0.5Hz) or 24mA (1Hz); At 18Vdc: 18.5mA (0.5Hz) or 30mA (1Hz)
Product dimensions (mm)	108mm diameter x 99mm deep
IP Rating	IP21C (Type A).
Weight	230g.
Operating conditions/temperature	-10°C to +55°C. Max. 95% RH (Non-condensing).



T 01942 322744 E sales@c-tec.co.uk  
F 01942 829867 W www.c-tec.com



C-TEC, Challenge Way, Martland Park, Wigan, WN5 0LD United Kingdom